



2024-13-PW - Elmvale WWTP Upgrades

Addendum # 1

Question 1:

Please confirm that Trueline can be listed as an acceptable manufacturer for the Knife Gate Valves specified in section 15205.2.6. Knife Gates manufactured by Trueline comply with the specification as written and include a sharp knife shaped leading edge. Their valves are manufactured out of cast 316 stainless steel and have 316 stainless steel stems. Trueline manufactured Knife Gates have been installed throughout Ontario for the past 30+ years.

Answer 1:

Yes. Trueline is an acceptable manufacturer for knife gate valves.

Question 2:

Will there be a pre-tender site visit for this project?

Answer 2:

A pre-tender site visit is scheduled for December 5, 2024 @ 10am at the Elmvale WWTP locate 1128 Flos Rd. 10 East, Elmvale, Ontario. Personal Protective Equipment is required including CSA approved safety shoes, safety vest and hard hat.