



ADDENDUM No. 3

Date Issued: February 6, 2025

To: All Bidders

Subject: Amendment to RFT ISD24-134 Request for Tender (RFT) for Wanapitei Water Treatment Plant Filter Upgrades

The following information, amendments, and revisions shall form an integral part of the Bid Solicitation Documents and where applicable, shall supersede requirements of other Bid Solicitation Documents. Refer to Section 5.1.3 of the Bid Solicitation.

1. Amendment: RFT – Section 6. Documents Available for Download on bids&tenders

ADD:

- Filter Sand & Gravel SDS
- Anthrafilter Anthracite Coal SDS

QUESTIONS & ANSWERS:

Question 1:

Can you confirm the thickness of the existing concrete slab to be removed? C7151-3-Demolition & Removals.

Answer 1:

The thickness of the existing concrete slab to be removed is approximately 100 - 150 mm thick.

Question 2:

An MTO aggregate mix is noted in the concrete mix, is this required? Or will a CSA mix be acceptable?

Answer 2:

A CSA concrete mix is acceptable.

Question 3:

Are you able to provide an SDS for the media, sand and anthracite?

Answer 3:

Refer to Amendment 1. The SDS documents are available for download on bids&tenders.

****End of Addendum****